O'Neill Pumping Plant Circuit Breaker Replacement Project

South-Central California Area Office

Date: August 17, 2009

		111/	11
To:	Wildlife Biologist	SCC 420 WKinsey	717/09
	Natural Resource Specialist	SCC 413 R Healer	8/19/09
	Natural Resource Specialist	SCC 423 25 N Gruenhagen	8/19/09
	Secretary	SCC 101 P Escobar	800
	Chief, Resource Division	SCC 400 L Myers	3/31
	Deputy Area Manager	SCC 430 T Buelna	431
	Natural Resource Specialist	SCC 413 R Healer	831/09

Cost Authority Number: 12519103041001910S (WOID 417)

From: Rain Healer

Subject: Review and signing of Categorical Exclusion Checklist

Please review the attached CEC and route it according to the order on the list. When your review is finished, please date, initial and sign on the last page. However, if you have comments or questions please contact the Environmental Team or the proponent of the action. When everyone has signed the CEC, please return it to Rain Healer.

Thank you.

Copies to:

Ready for Central Files

MP-3730 (1 Copy)

Natural Resources Specialist (1 Copy): Rain Healer - SCC-413

Project Lead (1 Copy): Victor Yue – MP200 RMD Files (E-Copy): Kiran Grewal SCC-417

CATEGORICAL EXCLUSION CHECKLIST O'Neill Pumping Plant Circuit Breaker Replacement Project

South-Central California Area Office

August 5, 2009

Background: The American Recovery and Reinvestment Act of 2009 (Act) is an economic stimulus package, worth up to \$787 billion, which was signed into law on February 17, 2009 for the purpose of stimulating the United States economy during a significant economic downturn. The Department of the Interior has been tasked with managing \$3 billion in investments as part of the Act in order to jumpstart the economy, create or save jobs, and address long-neglected challenges. Of the \$3 billion, one billion will be invested in water infrastructure across the United States by the Bureau of Reclamation (Reclamation). Out of this, \$260 million will go to projects in California that will expand water supplies, repair aging water infrastructure, and mitigate the effects of a devastating drought the state is currently experiencing. An additional \$135 million is available for grants for water reuse and recycling projects.

The O'Neill Pump-Generating Plant (O'Neill), a Reclamation facility constructed between 1964-67, is located within the San Luis Dam quadrangle, Section 1, Township 10 south, Range 8 east, Merced County, California,12 miles west of the City of Los Banos (Figure 1). O'Neill consists of an intake channel leading off the Delta-Mendota Canal and six pump-generating units (Figure 2). These units consist of two sets of circuit breakers. One circuit breaker set turns the pumps on and off and allows the units to operate as pumps to lift water from 45 to 53 feet into the O'Neill Forebay. The circuit breaker set, operates as generators when water is occasionally released from the forebay to the Delta-Mendota Canal. When operating as pumps and motors, each unit can discharge 700 cubic feet per second and has a rating of 6,000 horse-power. When operating as turbines and generators, each unit has a generating capacity of about 4,200 kilowatts.

Part of the Act funding has been awarded to replace and upgrade the switchgear circuit breakers at O'Neill that are used for pumping water and generating electricity.

<u>Proposed Action</u>: Reclamation proposes to replace and upgrade the existing switchgear circuit breakers at O'Neill. The Proposed Action includes:

- Inspection of existing power circuit breakers and switchgear lineups.
- Purchase, testing, and installation of twelve 4,160 volt replacement power circuit breakers.
- Removal and disposal of 12 existing power circuit breakers from the switchgear lineups.
- Installation of a computerized remote racking system within the existing switchgear cabinet, including modifications of the control circuits of the racking mechanism. The remote racking system is a computerized system that


mechanically pushes breakers into the lineup allowing employees to be further away from electrical equipment during maintenance.

The new racking system and circuit breakers would be tested in the field in conjunction with the existing switchgear lineups.

All work to be done is within existing equipment. No new construction or ground disturbance is associated with the Proposed Action.

Purpose of Action: The purpose of the action is to replace older circuit breakers and to upgrade the switchgear lineup by adding a remote racking system that would allow for mechanical instead of manual manipulation of electrical equipment providing a safer working environment.

Exclusion Category: 516 DM 14.5 D (1). Maintenance, rehabilitation, and replacement of existing facilities which may involve a minor change in size, location, and/or operation.



Evaluation of Criteria for Categorical Exclusion

1. This action or group of actions would have a significant effect on the quality of the human environment.	No <u>X</u>	Uncertain	Yes
2. This action or group of actions would involve unresolved conflicts concerning alternative uses of available resources.	No X	Uncertain	Yes
Evaluation of Exemptions to Actions within	Categorical Exc	clusion	
1. This action would have significant adverse effects on public health or safety.	No <u>X</u>	Uncertain	Yes
2. This action would have an adverse effect on unique geological features such as wetlands, wild or scenic rivers, refuges, flood plains, rivers placed on the nationwide river inventory, or prime or unique farmlands. (Same as 516 DM 2, Appendix 2, Part 2.2).	No X	Uncertain	Yes
3. This action will have highly controversial environmental effects.	No <u>X</u>	Uncertain	Yes
4. This action will have highly uncertain environmental effects or involve unique or unknown environmental risks.	No <u>X</u>	Uncertain	Yes
5. This action will establish a precedent for future actions.	No <u>X</u>	Uncertain	Yes
6. This action is related to other actions with individually insignificant but cumulative significant environmental effects.	No <u>X</u>	Uncertain	Yes

7. This action will affect properties listed or eligible to be listed in the National Register of Historical Places.			No <u>X</u>	Uncertain	Yes
species li		ll adversely affect a osed to be listed as ned.	No <u>X</u>	Uncertain	Yes
9. This action threatens to violate Federal, State, Local or Tribal law or requirements imposed for protection of the environment.			No <u>X</u>	Uncertain	Yes
10. This action will affect Indian Trust Assets.			No <u>X</u>	Uncertain	Yes
		ll disproportionately -income populations.	No <u>X</u>	Uncertain	Yes
NEPA A	ction:	Categorical Exclusion X	_ EA	EIS	
Environi	mental comi	nitments, explanation, and	or remarks:		
□Yes	⊠No	Environmental commitmen	ts are required	and attached.	
	San Joaquin Kit Fox Avoidance and Minimization Measures				
	Giant Garter Snake Avoidance and Minimization Measures				
	California Tiger Salamander Avoidance and Minimization Measures				
	California Red-Legged Frog Avoidance and Minimization Measures				
	Other:				

Air Quality:There are no air quality emissions associated with this project; therefore, there are no impacts to air quality.

.

Prepared by:			
Rain Healer	Date: August 17, 2009		
South-Central California Area Office	spends broad approposed to be fisted as enclanaged in		
Regional Archeologist concurrence with Item See attachment.	n 7:		
ITA Designee concurrence with Item 10: See attachment.	consumers imposed for protection of dis- unctioned.		
Concur:			
Supervisory Natural Resource Specialist, Son	Date: 08/28/09		
Supervisory Natural Resource Specialist, Sou	uth-Central California Area Office		
Concur.			
Mulan Jan	Date: 08/17/2009		
Wildlife Biologist, South-Central California	Area Office		
Concur:			
Mille Wight	Date: 8/3//07		
Chief, Resources Management Division, Sou	uth-Central California Area Office		
Approved	Date: 8 21 59		
Deputy Area Manager, South-Central Califo	rnia Area Office		

Healer, Rain L

From: Kinsey, Charles M (Michael)

Sent: Monday, August 17, 2009 10:19 AM

To: Healer, Rain L

Subject: RE: CEC-09-125 O'Neill Pumping Plant Circuit Breaker Replacement Project

Rain.

As this project is taking place entirely within an existing facility, involves no construction or ground disturbance, and will not change the uses of the facility or the amounts of water available to listed species, there will be no effect to listed species or critical habitats. Bring the folder by and I will sign off on it.

Mike K

Michael Kinsey Supervisory Wildlife Biologist U.S. Bureau of Reclamation South-Central California Area Office 1243 'N' Street Fresno, CA 93721 559-487-5139 (direct) 559-487-5397 (fax) 559-905-0279 (cell)

From: Healer, Rain L

Sent: Monday, August 17, 2009 7:37 AM

To: Barnes, Amy J; Bruce, Brandee E; Connolly, Jonathan D; Leigh, Anastasia T; Morris, Peter J; Nickels, Adam M; Overly,

Stephen A; Gruenhagen, Ned M; Kinsey, Charles M (Michael); Lewis, Jennifer; McDonald, Shauna A

Subject: CEC-09-125 O'Neill Pumping Plant Circuit Breaker Replacement Project

I have attached a new CEC for review.

Cost authority: 12519103041001910S (WOID 417)

This is an ARRA project

Rain L. Healer
Natural Resource Specialist
Bureau of Reclamation
1243 N Street, SCC 413
Fresno, CA 93721
(559) 487-5196
rhealer@usbr.gov

Healer, Rain L

From: Nickels, Adam M

Sent: Monday, August 17, 2009 9:04 AM

To: Healer, Rain L; Barnes, Amy J; Bruce, Brandee E; Connolly, Jonathan D; Leigh, Anastasia T;

Overly, Stephen A; Gruenhagen, Ned M; Kinsey, Charles M (Michael); Lewis, Jennifer;

McDonald, Shauna A

Subject: RE: CEC-09-125 O'Neill Pumping Plant Circuit Breaker Replacement Project

Project No 09-SCAO-312

Rain:

The Proposed undertaking to conduct repair and maintenance of the O'Neil Pumping Plant, a Reclamation facility, has no potential to affect historic properties pursuant to the regulations at 36 CFR Part 800.3(a)(1).

The proposed action involves the removal and replacement of 12 existing circuit breakers within existing circuit breaker cabinents and the installation of a computerized racking system within an existing switchgear cabinet. The purpose of these improvements is to improve the reliability and technology of the electrical distributions systems at O'Neil Pumping Plant. The work will require no modification or addition to existing structures. There will be no ground disturbance or physical modification of structures as a result of this undertaking.

I concur with line 7 of CEC 09-125 Dated August 5, 2009 for the O'Neil Pumping Plant Circuit Breaker Replacement Project.

Location: O'Neil Forebay, near San Luis Dam, Merced County, CA

Exclusion: D(1)

This concludes the Section 106 process for this undertaking.

Sincerely,

Adam M. Nickels, M.S. Archeologist Bureau of Reclamation Mid-Pacific Regional Office, MP-153 2800 Cottage Way Sacramento, California 95825

Phone: 916.978.5053 Fax: 916978.5055

From: Healer, Rain L

Sent: Monday, August 17, 2009 7:37 AM

To: Barnes, Amy J; Bruce, Brandee E; Connolly, Jonathan D; Leigh, Anastasia T; Morris, Peter J; Nickels, Adam M; Overly,

Stephen A; Gruenhagen, Ned M; Kinsey, Charles M (Michael); Lewis, Jennifer; McDonald, Shauna A

Subject: CEC-09-125 O'Neill Pumping Plant Circuit Breaker Replacement Project

I have attached a new CEC for review.

Cost authority: 12519103041001910S (WOID 417)

This is an ARRA project

Rain L. Healer Natural Resource Specialist Bureau of Reclamation 1243 N Street, SCC 413 Fresno, CA 93721 (559) 487-5196 rhealer@usbr.gov

Healer, Rain L

From:

Rivera, Patricia L

Sent:

Monday, August 17, 2009 2:23 PM

To:

Healer, Rain L

Subject:

RE: CEC-09-125 O'Neill Pumping Plant

Rain

I reviewed the proposed action to replace and upgrade the existing switchgear circuit breakers at O'Neill. The Proposed Action includes:

- Inspection of existing power circuit breakers and switchgear lineups.
- Purchase, testing, and installation of twelve 4,160 volt replacement power circuit breakers.
- Removal and disposal of 12 existing power circuit breakers from the switchgear lineups.
- Installation of a computerized remote racking system within the existing switchgear cabinet, including
 modifications of the control circuits of the racking mechanism. The remote racking system is a computerized
 system that mechanically pushes breakers into the lineup allowing employees to be further away from electrical
 equipment during maintenance.

The new racking system and circuit breakers would be tested in the field in conjunction with the existing switchgear lineups.

All work to be done is within existing equipment. No new construction or ground disturbance is associated with the Proposed Action.

The O'Neill Pump-Generating Plant (O'Neill), a Reclamation facility constructed between 1964-67, is located within the San Luis Dam quadrangle, Section 1, Township 10 south, Range 8 east, Merced County, California,12 miles west of the City of Los Banos. O'Neill consists of an intake channel leading off the Delta-Mendota Canal and six pump-generating units. Normally these units operate as pumps to lift water from 45 to 53 feet into the O'Neill Forebay. Water is occasionally released from the forebay to the Delta-Mendota Canal, and these units then operate as generators. When operating as pumps and motors, each unit can discharge 700 cubic feet per second and has a rating of 6,000 horse-power. When operating as turbines and generators, each unit has a generating capacity of about 4,200 kilowatts.

Part of the Act funding has been awarded to replace and upgrade the switchgear circuit breakers at O'Neill.

The proposed action does not affect Indian Trust Assets. The nearest ITA is Chicken Ranch Rancheria approximately 66 miles NE of the project location.

Patricia

SECTION 01110 - SUMMARY OF WORK

PART 1 GENERAL

1.01 LOCATION

A. Work is located in the O'Neill Pumping-Generating Plant approximately 12 miles west of Los Banos, Merced County, California.

1.02 PRINCIPAL COMPONENTS OF WORK

- A. Inspect existing power circuit breakers and switchgear lineups at the jobsite.
- B. Furnish and factory test twelve new replacement power circuit breakers.
- C. Remove and dispose of twelve existing power circuit breakers from the switchgear lineups.
- D. Install a remote racking system and modify control circuits of racking mechanism.
- E. Install twelve new replacement power circuit breakers.
 - F. Test twelve new replacement power circuit breakers in conjunction with existing switchgear lineups in the field.
 - G. Test the remote racking system in the field.

1.03 SPECIFICATIONS REQUIREMENTS

- A. Requirements in Division 1 General Requirements apply to Divisions 2 through 16.
- B. Imperative statements in these specifications are Contractor requirements, unless otherwise stated.
- C. Where specifications are written in streamlined form, the words "shall be" are included by inference where a colon (:) is used within the sentence or phrase.

1.04 DEFINITIONS

A. When the specifications use a word or term defined in the Federal Acquisition Regulations (FAR), the definition of the word or term shall be in accordance with FAR sections in effect at the time the solicitation was issued.

1.05 ACRONYMS

- A. The following acronyms apply to specifications Divisions 1 through 16:
 - 1. CO: Contracting Officer
 - COR: Contracting Officer's Representative

- 3. CE: Construction Engineer.
- 4. OGR Onsite Government Representative.

PART 2 PRODUCTS

Not Used

PART 3 EXECUTION

Not Used

END OF SECTION

Pone by Reclamation or DMC Authority?

Still inide cabinet -> doing work for us instead of cabinet motorized put into same calinet Can send spec if I want